

Midas[®] SENSOR CARTRIDGE SPECIFICATIONS

HCl Group MIDAS-S-HCL, MIDAS-E-HCL



Gas Measured	Hydrogen Chloride (HCl)
Cartridge Part Number	MIDAS-S-HCL 1 year extended warranty MIDAS-E-HCL 2 year extended warranty
Sensor Technology	3 electrode electrochemical cell
Measuring Range (ppm)	HCl 0 – 8ppm
Minimum Alarm 1 Set Point	1ppm
Repeatability	< ± 10% of measured value
Linearity	< ± 20% of measured value
Response Time	$t_{62.5}$ < 30 seconds based on 3 min. exposure t_{90} < 140 seconds based on 3 min. exposure
Sensor Cartridge Life Expectancy	24 months under typical application conditions
Operating Temperature	0°C to +40°C (32°F to 104°F)
Effect of Temperature	< ± 0.001ppm / °C (0°C to 20°C) < ± 0.005ppm / °C (20°C to 40°C)
Zero Sensitivity	< ± 0.4% of measured value / °C
Operating Humidity (continuous)	20 – 75% rH
Effect of Humidity	< ± 0.002ppm / % rH < ± 0.4% of measured value / % rH
Operating Pressure	90 – 110kPa
Effect of Position	No effect in typical application
Long Term Drift	
Zero Sensitivity	Negligible < 15% of measured value / year
Calibration Gas	Hydrogen Chloride (4-6ppm HCl)
Challenge Gas (Bump Test)	Hydrogen Chloride (4-6ppm HCl)
Warm Up Time	< 20 minutes
Storage Temperature	+5°C to +25°C (+41°F to +77°F)

The sensor data listed is based on the test data under normal Lab test conditions (20-25 C, 0 - 60%RH, normal atmosphere pressure); observed performance may vary based on the actual monitoring system and the sampling conditions employed

Other Detectable Gases

The following additional gases can be detected with this sensor cartridge. Sensor performance and characteristics will be representative of the data as tabulated above. Consult the Technical Manual to set up the Midas[®] transmitter with the designated identification code for each of the following gas types.

Detectable Gas	Chemical Formula	Measuring Range
Dichlorosilane	H ₂ SiCl ₂	0 – 8ppm
Boron Trichloride	BCl ₃	0 – 8ppm
Hydrogen Bromide	HBr	0 – 8ppm

Cross Sensitivities

Each Midas[®] sensor is potentially cross sensitive to other gases and this may cause a gas reading when exposed to other gases than those originally designated. The table below presents typical readings that will be observed when a new sensor cartridge is exposed to the cross sensitive gas (or a mixture of gases containing the cross sensitive species).

Gas / Vapor	Chemical Formula	Concentration Applied (ppm)	Reading (ppm HCl)
Arsine	AsH ₃	1	0
Carbon Monoxide	CO	2000	0
Chlorine	Cl ₂	5	5.6
Diborane	B ₂ H ₆	1	-1.3
Hydrogen	H ₂	20000	0
Hydrogen Fluoride	HF	5	6.7
Hydrogen Sulfide	H ₂ S	25	-3.6
Iso Propanol	C ₃ H ₇ OH	500	0
Methanol	CH ₃ OH	500	0
Nitrogen Dioxide	NO ₂	5	0.9
Phosphine	PH ₃	1	-0.14
Sulfur Dioxide	SO ₂	10	4.5

Find out more

www.honeywellanalytics.com

Toll-free: 800.538.0363

Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.

DSA Suppliers

Thank you for reading this. For pricing or further information, please contact us.

W: <https://dsasuppliers.com>

E: sales@dsasuppliers.com

P: +441158390391

Leading UK Supplier
Brand New & Genuine OEM Parts
Delivered Worldwide



Worldwide Delivery



1000+ Genuine Parts & Equipment

Please Note - The information, product designs & specifications in this document are subject to change without notice.
DSA Suppliers is not responsible for determining the suitability of this product.